



	<b>TECHNICAL SPECIFICATION</b>	<b>Doc Number:</b> CO.14900.TCSP.000162  <b>Version:</b> 1
<b>SPMS ARTICLE CODE:</b> 082301-0115	<b>DESCRIPTION OF MATERIAL:</b> CLAMP P/G ALUMINIUM/ALUMINIUM 100/100 MM2	<b>Page 1 of 3</b>

### SCHEDULE A: MINIMUM ZESCO REQUIREMENTS

S/N	TYPE	CONDUCTOR CROSS SECTION AREAS (mm <sup>2</sup> )	NUMBER AND MATERIAL OF BOLT	CLAMP BODY MATERIAL	DIMENSIONS
1.	Aluminium/Aluminium conductor connection	100/100	2 X Galvanised mild steel bolts	Aluminium	As per Drawing No.E11389 shown below
	<b>Other dimensions</b>				
2.	Drawings showing dimensions to be provided with bid	Yes/No	Yes		
3.	Previous type tests results/certificate to be provided with bid	Yes/No	Yes		
4.	Quality assurance certificate to be provided with bid	Yes/No	Yes		
5.	Applicable standard		IEC standards		

Prepared By	Date	Reviewed By	Date	Approved By	Date
 Felix S. Benyeli	25/11/2015	 Daniel Sichela	25/11/15	 Bright Sepiso	30/11/2015

 <p><b>ZESCO</b> Powering the Nation</p>	<p align="center"><b>TECHNICAL SPECIFICATION</b></p>	<p><b>Doc Number:</b> CO.14900.TCSP.000162</p> <p><b>Version: 1</b></p>
<p><b>SPMS ARTICLE CODE:</b> 082301-0115</p>	<p><b>DESCRIPTION OF MATERIAL:</b> CLAMP P/G ALUMINIUM/ALUMINIUM 100/100 MM2</p>	<p align="right"><b>Page 2 of 3</b></p>





FIG 1-Drawing showing dimensions for a universal GP clamp

	<b>TECHNICAL SPECIFICATION</b>	<b>Doc Number:</b> CO.14900.TCSP.000162  <b>Version:</b> 1
<b>SPMS ARTICLE CODE:</b> 082301-0115	<b>DESCRIPTION OF MATERIAL:</b> CLAMP P/G ALUMINIUM/ALUMINIUM 100/100 MM2	<b>Page 3 of 3</b>

**SCHEDULE B: TO BE COMPLETED BY SUPPLIER.**

S/N	TYPE	CONDUCTOR CROSS SECTION AREAS (mm <sup>2</sup> )	NUMBER AND MATERIAL OF BOLT	CLAMP BODY MATERIAL	DIMENSIONS
1.					
	<b>Other requirements</b>				
2.	Drawings showing dimensions to be provided with bid	Yes/No			
3.	Previous type tests results/certificate to be provided with bid	Yes/No			
4.	Quality assurance certificate to be provided with bid	Yes/No			
5.	Applicable standard				